



Office of the Chief Fire Officer
Pune Municipal Corporation
Out W.No : FB/ 799
Date : 28/5/2022

(KDB/0016/03)

To,

Jagdish P. Deshapande Architects,
Deccan Gymkhana, Pune.

Sub :- Final Fire NOC for the Primary & High School building at S No.63/2 (P), Plot No.1, Kondhwa Bk., Pune.

(For building height- 30.00 Mtrs. & Built up Area-9194.44 Sq.Mtrs. Only)

Ref :- Your Office letter Dt.26.05.2022.

Sir,


As per your request, visited the proposed site along with Mr. Paresh Porwal on Dt.26.05.2022 and tested the Hydrant system, Hose Reel system with equipments and portable fire extinguishers suggested in Revised Provisional N.O.C. issued vide No. FB/399, Dt.02.05.2022 issued by Fire Department.

The suggestions made in Revised Provisional N.O.C. are carried out to my satisfaction and I have No Objection to use the building for proposed purpose. M/s.Vista Corporation, Pune submitted the "FORM A" to this office for the fire prevention, protection & fire fighting system installed in the above said building as per The Maharashtra Fire Prevention & Life Safety Measures Act 2006.

The fire fighting equipments and systems installed in the building should be maintained in high efficiency state and in proper working order at all time during the use of the building by owner or occupier. It will be your responsibility to get the yearly renewal of this Fire NOC after due inspection from the Fire Brigade authorities. The maintenance work of the fire-fighting-system shall be done by the licensed contractor, having license from Director, Maharashtra Fire services or Chief Fire Officer, Pune Fire Brigade. The list of the license contractor is available on [/www.maharashtrafireservices.org](http://www.maharashtrafireservices.org).

Name of the person, owner, responsible for the building maintenance should be informed to this office. Fire protection system provided in the building should not be removed from the building for any reason.

This Final No objection is subjected to any other conditions laid by any other department.


(Sunil T. Gilbile)

I/c. Chief Fire Officer
Pune Municipal Corporation

Copy to : Dy. Engineer (B.C.),
Pune Municipal Corporation.